

# Certificate of compliance

**Applicant:** Anker Innovations Limited  
Unit 56, 8th Floor, Tower 2, Admiralty Centre, 18 Harcourt Road  
Central and Western District, HONG KONG  
P. R. China

**Product:** Photovoltaic and battery inverter

**Model:** X1-H5K-T  
X1-H8K-T  
X1-H10K-T

**Use in accordance with regulations:**

Automatic disconnection device with three-phase mains surveillance in accordance with Engineering Recommendation G98/1 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter. This serves as a replacement for the disconnection device with isolating function, which can be accessed the distribution network provider at any time.

**Applied rules and standards:**

**Engineering Recommendation G98/1-7:2022**

Requirements for the connection of Fully Type Tested Micro-generators (up to and including 16 A per phase) in parallel with public Low Voltage Distribution Networks

At the time of issue of this certificate, the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

**Report number:** HC2412110295GC01-R1

**Certification  
Program:**


**NSOP-0032-DEU-ZE-V10**

**Certificate number:** U25-0324

**Date of issue:**

**2025-03-31**

**Accreditation**



Accredited certification body by Deutsche Akkreditierungsstelle GmbH (DAkkS) according to ISO/IEC 17065. The accreditation is valid only for the scope listed in the annex of the accreditation certificate D-ZE-12024-01-00. The Deutsche Akkreditierungsstelle GmbH (DAkkS) is signatory of the multilateral arrangements of EA, ILAC and IAF for mutual recognition.

Without the written consent of Bureau Veritas Consumer Products Services Germany GmbH excerpts of this certificate of conformity shall not be reproduced.