

# CERTIFICATE OF COMPLIANCE

**Certificate Number:** SGSNA/25/GZ/00416X

**Contract Number:** 800833  
**Certificate Project Number:** GZ-CERT251004296

**Certified Product:** Combiner Box(ISE)  
**Trademarks:** ANKER  
**Model(s):** AX170-COMBINER  
**Technical Data:** Nominal Output Voltage (ac):120/240Vac  
Each AC Port Continuous Input and Output:100A Max, 24kW Max, 60Hz, L1+L2+N+PE  
Total Continuous Input and Output: 160A Max, 38.4kW Max, 60Hz, L1+L2+N+PE  
Operating Temperature: -20°C to 55°C  
Enclosure Type: Type 3R

**Certificate Holder:** Anker Innovations Limited  
Unit 56, 8th Floor, Tower 2, Admiralty Centre, 18 Harcourt Road, Hong Kong, China

*This certificate supercedes previous certificates issued with the same certificate number. Certification is valid when products are indicated on the SGS directory of certified products at [www.sgs.com](http://www.sgs.com) or using the QR code below. The product is certified according to ISO/IEC Guide 17067, Conformity assessment - Fundamentals of product certification, System 3, and in accordance with:*

UL 1741, Third Edition, Dated September 28, 2021  
CSA C22.2 No. 107.1:16 (reaffirmed 2021)

### Certification Condition

The model AX170-COMBINER is to be installed in accordance with the National Electrical Code NFPA 70 (National Electric Code) or CSA C22.1 (Canadian Electric Code) and Installation of Stationary Energy Storage Systems, NFPA 855 by end user.

Authorized by:

Effective date: 07 November 2025

Jason Wei  
Certifier



### Certification Body

Connectivity & Products, a division of SGS North America Inc.  
620 Old Peachtree Road, Ste. 100, Suwanee, GA 30024, USA  
t +1 770 570 1800 f +1 770 277 1240 [www.sgs.com](http://www.sgs.com)

