



Product Service

Attestation of Conformity

No. N8A 135260 0016 Rev. 01

Holder of Attestation: **Anker Solix Innovations Limited**

Flat/RM 829, 8/F, Tower 2
Admiralty Centre, 18 Harcourt Road
Central and Western District
HONG KONG

Product: **Low voltage switchgear combination**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 64290253192702

Date, 2026-04-10

(Billy Qiu)

Page 1 of 5

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Attestation of Conformity

No. N8A 135260 0016 Rev. 01

Model(s): **Power Dock Pro 63-S-AU,**
 Power Dock Pro 63-T-AU,
 Power Dock Pro 63-S-EU,
 Power Dock Pro 63-T-EU.
 Power Dock Pro 63-S0-AU,
 Power Dock Pro 63-T0-AU,
 Power Dock Pro 63-S0-EU,
 Power Dock Pro 63-T0-EU.

Parameters:

Model	Power Dock Pro 63-T-EU, Power Dock Pro 63-T-AU	Power Dock Pro 63-S-EU, Power Dock Pro 63-S-AU
Grid terminal input/output rating		
Rated input/output voltage [V a.c.]	380/400, L1+L2+L3+N+PE	220/230/240, L+N+PE
Rated input/output frequency [Hz]	50/60	50/60
Rated continuous input/output current [A a.c.]	63	63
Max. continuous input/output current [A a.c.]	63	63
INV1 or INV2 terminal input/output rating		
Rated input/output voltage [V a.c.]	380/400, L1+L2+L3+N+PE	220/230/240, L+N+PE
Rated input/output frequency [Hz]	50/60	50/60
Rated continuous input/output current [A a.c.]	45.6	54.6
Max. continuous input/output current [A a.c.]	45.6	54.6
Max. total of INV1, INV2 continuous input/output current [A a.c.]	54.6	54.6
Smart terminal input/output rating		
Rated input/output voltage [V a.c.]	380/400, L1+L2+L3+N+PE	220/230/240, L+N+PE
Rated input/output frequency [Hz]	50/60	50/60

Page 2 of 5

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Attestation of Conformity

No. N8A 135260 0016 Rev. 01

Rated continuous input/output current [A a.c.]	45.6	45.6
Max. continuous input/output current [A a.c.]	45.6	45.6
Max. total of Smart, INV1, INV2 continuous input/output current [A a.c.]	63	63
Backup terminal input/output rating		
Rated input/output voltage [V a.c.]	380/400, L1+L2+L3+N+PE	220/230/240, L+N+PE
Rated input/output frequency [Hz]	50/60	50/60
Rated continuous input/output current [A a.c.]	63	63
Max. continuous input/output current [A a.c.]	63	63
Non-Backup terminal input/output rating		
Rated input/output voltage [V a.c.]	380/400, L1+L2+L3+N+PE	220/230/240, L+N+PE
Rated input/output frequency [Hz]	50/60	50/60
Rated continuous input/output current [A a.c.]	63	63
Max. continuous input/output current [A a.c.]	63	63
General		
Ingress protection rating	IP55	
Ambient temperature range [°C]	-20~55	
Protective class	Class I	

Page 3 of 5

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Attestation of Conformity

No. N8A 135260 0016 Rev. 01

Model	Power Dock Pro 63-T0-EU, Power Dock Pro 63-T0-AU	Power Dock Pro 63-S0-EU, Power Dock Pro 63-S0-AU
Grid terminal input/output rating		
Rated input/output voltage [V a.c.]	380/400, L1+L2+L3+N+PE	220/230/240, L+N+PE
Rated input/output frequency [Hz]	50/60	50/60
Rated continuous input/output current [A a.c.]	63	63
Max. continuous input/output current [A a.c.]	63	63
INV1 or INV2 terminal input/output rating		
Rated input/output voltage [V a.c.]	380/400, L1+L2+L3+N+PE	220/230/240, L+N+PE
Rated input/output frequency [Hz]	50/60	50/60
Rated continuous input/output current [A a.c.]	25	30
Max. continuous input/output current [A a.c.]	25	30
Max. total of INV1, INV2 continuous input/output current [A a.c.]	50	54.6
Smart terminal input/output rating		
Rated input/output voltage [V a.c.]	380/400, L1+L2+L3+N+PE	220/230/240, L+N+PE
Rated input/output frequency [Hz]	50/60	50/60
Rated continuous input/output current [A a.c.]	45.6	45.6
Max. continuous input/output current [A a.c.]	45.6	45.6
Max. total of Smart, INV1, INV2 continuous input/output current [A a.c.]	63	63
Backup terminal input/output rating		

Page 4 of 5

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

Attestation of Conformity

No. N8A 135260 0016 Rev. 01

Rated input/output voltage [V a.c.]	380/400, L1+L2+L3+N+PE	220/230/240, L+N+PE
Rated input/output frequency [Hz]	50/60	50/60
Rated continuous input/output current [A a.c.]	63	63
Max. continuous input/output current [A a.c.]	63	63
Non-Backup terminal input/output rating		
Rated input/output voltage [V a.c.]	380/400, L1+L2+L3+N+PE	220/230/240, L+N+PE
Rated input/output frequency [Hz]	50/60	50/60
Rated continuous input/output current [A a.c.]	63	63
Max. continuous input/output current [A a.c.]	63	63
General		
Ingress protection rating	IP55	
Ambient temperature range [°C]	-20~55	
Protective class	Class I	

Tested according to:

EN 62109-1:2010
 EN 62109-2:2011
 EN 61439-1:2011
 EN 61439-2:2011

Page 5 of 5

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.