



Product Service

Attestation of Conformity

No. E8A 135260 0020 Rev. 01

Holder of Attestation: **Anker Solix Innovations Limited**

Flat/RM 829, 8/F, Tower 2
Admiralty Centre, 18 Harcourt Road
Central and Western District
HONG KONG

Name of Object: **Low voltage switchgear combination**

This Attestation of Conformity is issued on a voluntary basis according to the Directive 2014/30/EU relating to electromagnetic compatibility. It confirms that the listed apparatus complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 64772253192902

Date, 2026-04-09

(Samuel Zhang)

Page 1 of 4

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

Attestation of Conformity

No. E8A 135260 0020 Rev. 01

Model(s): Power Dock Pro 63-S-AU, Power Dock Pro 63-T-AU, Power Dock Pro 63-S-EU, Power Dock Pro 63-T-EU, Power Dock Pro 63-S0-AU, Power Dock Pro 63-T0-AU, Power Dock Pro 63-S0-EU, Power Dock Pro 63-T0-EU.

Trade name: ANKER SOLIX

Description of Object:

Model	Power Dock Pro 63-T-EU, Power Dock Pro 63-T-AU	Power Dock Pro 63-S-EU, Power Dock Pro 63-S-AU
Grid terminal input/output rating		
Rated input/output voltage [V a.c.]	380/400, L1+L2+L3+N+PE	220/230/240, L+N+PE
Rated input/output frequency [Hz]	50/60	50/60
Rated continuous input/output current [A a.c.]	63	63
Max. continuous input/output current [A a.c.]	63	63
INV1 or INV2 terminal input/output rating		
Rated input/output voltage [V a.c.]	380/400, L1+L2+L3+N+PE	220/230/240, L+N+PE
Rated input/output frequency [Hz]	50/60	50/60
Rated continuous input/output current [A a.c.]	45.6	54.6
Max. continuous input/output current [A a.c.]	45.6	54.6
Max. total of INV1, INV2 continuous input/output current [A a.c.]	54.6	54.6
Smart terminal input/output rating		
Rated input/output voltage [V a.c.]	380/400, L1+L2+L3+N+PE	220/230/240, L+N+PE
Rated input/output frequency [Hz]	50/60	50/60
Rated continuous input/output current [A a.c.]	45.6	45.6
Max. continuous input/output current [A a.c.]	45.6	45.6
Max. total of Smart, INV1, INV2 continuous input/output current [A a.c.]	63	63

Page 2 of 4

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

Attestation of Conformity

No. E8A 135260 0020 Rev. 01

Backup terminal input/output rating		
Rated input/output voltage [V a.c.]	380/400, L1+L2+L3+N+PE	220/230/240, L+N+PE
Rated input/output frequency [Hz]	50/60	50/60
Rated continuous input/output current [A a.c.]	63	63
Max. continuous input/output current [A a.c.]	63	63
Non-Backup terminal input/output rating		
Rated input/output voltage [V a.c.]	380/400, L1+L2+L3+N+PE	220/230/240, L+N+PE
Rated input/output frequency [Hz]	50/60	50/60
Rated continuous input/output current [A a.c.]	63	63
Max. continuous input/output current [A a.c.]	63	63
General		
Ingress protection rating	IP55	
Ambient temperature range [°C]	-20~55	
Protective class	Class I	
Use environment	Residential	

Model	Power Dock Pro 63-T0-EU, Power Dock Pro 63-T0-AU	Power Dock Pro 63-S0-EU, Power Dock Pro 63-S0-AU
Grid terminal input/output rating		
Rated input/output voltage [V a.c.]	380/400, L1+L2+L3+N+PE	220/230/240, L+N+PE
Rated input/output frequency [Hz]	50/60	50/60
Rated continuous input/output current [A a.c.]	63	63
Max. continuous input/output current [A a.c.]	63	63
INV1 or INV2 terminal input/output rating		
Rated input/output voltage [V a.c.]	380/400, L1+L2+L3+N+PE	220/230/240, L+N+PE
Rated input/output frequency [Hz]	50/60	50/60
Rated continuous input/output current [A a.c.]	25	30
Max. continuous input/output current [A a.c.]	25	30

Page 3 of 4

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

Attestation of Conformity

No. E8A 135260 0020 Rev. 01

Max. total of INV1, INV2 continuous input/output current [A a.c.]	50	54.6
Smart terminal input/output rating		
Rated input/output voltage [V a.c.]	380/400, L1+L2+L3+N+PE	220/230/240, L+N+PE
Rated input/output frequency [Hz]	50/60	50/60
Rated continuous input/output current [A a.c.]	45.6	45.6
Max. continuous input/output current [A a.c.]	45.6	45.6
Max. total of Smart, INV1, INV2 continuous input/output current [A a.c.]	63	63
Backup terminal input/output rating		
Rated input/output voltage [V a.c.]	380/400, L1+L2+L3+N+PE	220/230/240, L+N+PE
Rated input/output frequency [Hz]	50/60	50/60
Rated continuous input/output current [A a.c.]	63	63
Max. continuous input/output current [A a.c.]	63	63
Non-Backup terminal input/output rating		
Rated input/output voltage [V a.c.]	380/400, L1+L2+L3+N+PE	220/230/240, L+N+PE
Rated input/output frequency [Hz]	50/60	50/60
Rated continuous input/output current [A a.c.]	63	63
Max. continuous input/output current [A a.c.]	63	63
General		
Ingress protection rating	IP55	
Ambient temperature range [°C]	-20~55	
Protective class	Class I	
Use environment	Residential	

Tested according to:

- EN IEC 61000-6-1:2019
- EN IEC 61000-6-3:2021
- EN 61439-1:2011
- EN IEC 61439-1:2021
- EN 61439-2:2011
- EN IEC 61439-2:2021

Page 4 of 4

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.