



CERTIFICATE

No. B 135260 0030 Rev. 00

Holder of Certificate: **Anker Solix Innovations Limited**

Flat/RM 829, 8/F, Tower 2
Admiralty Centre, 18 Harcourt Road
Central and Western District
HONG KONG

Certification Mark:



Product: **Electronic measuring equipment
(Anker SOLIX Smart Meter Gen 2)**

The product was tested on a voluntary basis and complies with the essential requirements.
The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier.
All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 64105263003001

Valid until: 2031-05-12

Date, 2026-05-13

Frank Zhu
(Frank Zhu)

CERTIFICATE

No. B 135260 0030 Rev. 00

Model(s): AE1X0311, AE1X0310

Parameters:

AC rated input:	3~ 230/400Va.c., 50/60Hz, 2W (for model AE1X0311); 230Va.c., 50/60Hz, 2W (for model AE1X0310)
Measuring current:	CT 40mA (connection through external current transformer)
Measurement category:	CAT III
IP protection class:	IP00
Protection class:	Built-in component, considered in end system
Remark: 1. The primary circuit and SELV circuit are evaluated to fulfill double insulation/reinforced insulation. 2. The smart meters are built-in components, protection against electric shock between the primary circuit and accessible parts depends on the end system. They shall be installed in a suitable electrical, fire and mechanical enclosure to meet the requirements of mentioned standard(s). 3. The smart meters without function of electric energy measurement and are not for metrology of electricity purpose which is under MID directive.	

Tested according to: EN 61010-1:2010/A1:2019
EN IEC 61010-2-030:2021/A11:2021